

State of California
Department of Public Health
Water Treatment Device
Certificate Number
05-1736

Date Issued: October 20, 2010

Trademark/Model Designation

Multi-Pure MPAD

Multi-Pure MPADC

Replacement Elements

CB6AD

CBTAD

Manufacturer: Multi-Pure Drinking Water Systems

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

Microbiological Contaminants and Turbidity

Cysts

Turbidity

Inorganic/Radiological Contaminants

Asbestos

Lead

Mercury

Organic Contaminants

Chlordane

MTBE

PCB

Toxaphene

VOCs

Rated Service Capacity: 750 gals

Rated Service Flow: 0.75 gpm

Conditions of Certification:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.